

Test Report

03.05.2019

Operator

CA Mätssystem AB
Björn Johansson
Sjöflygvägen 35

Stockholm, Täby 183 62
08-50 52 68 08

Test Site

CA Mätssystem AB
Björn Johansson
Sjöflygvägen 35

Täby, Stockholm 183 62
08-50 52 68 00


Modell: 6550, ID: 200545, Firmware: V3.1

Comments

Isolation 10kV.dvb



Index	Name
1	Objekt 2, Test 2 (R)



Test name	Objekt 2, Test 2 (R)	DAR	1,947
Function	Fast V	DAR1	1,553T Ω
Start Date	06.02.2018	DAR2	3,025T Ω
Start Time	14:54:46	PI	---- (Undefined)
Run-time	6:00 (min:s)	PI1	3,025T Ω
Voltage	10,17kV	PI2	---- Ω (Undefined)
Resistance	5,128T Ohm	DD	---- (Undefined)
R(t°ref)	---- Ohm (Undefined)	Capacitance	0,000F
		DD Current	----A (Undefined)

Objekt 2, Test 2 (R) (Ω)				
Index	Time	Val	Units	Samples
1	1,008 (s)	0,0	Ω	1
2	2,017 (s)	0,0	Ω	1
3	3,025 (s)	0,0	Ω	1
4	4,034 (s)	0,0	Ω	1
5	5,042 (s)	0,0	Ω	1
6	6,050 (s)	0,0	Ω	1
7	7,059 (s)	0,0	Ω	1
8	8,067 (s)	0,0	Ω	1
9	9,076 (s)	0,0	Ω	1
10	10,084 (s)	0,0	Ω	1
11	11,092 (s)	0,0	Ω	1
12	12,101 (s)	1,210	TΩ	1
13	13,109 (s)	1,196	TΩ	1
14	14,118 (s)	1,193	TΩ	1
15	15,126 (s)	1,255	TΩ	1
16	16,134 (s)	1,218	TΩ	1
17	17,143 (s)	1,523	TΩ	1
18	18,151 (s)	1,553	TΩ	1
19	19,160 (s)	1,553	TΩ	1
20	20,168 (s)	1,553	TΩ	1